



Government Of West Bengal
Office Of The Divisional Fire Officer
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.: FSR/0125186210600091

Date: 23-02-2024

From:

Divisional Fire Officer
Darjeeling Division (Member Convenor)
West Bengal Fire & Emergency Services

To: MOUNT LITERA ZEE SCHOOL

MADARIPUR, RAMGNAJ-II, ISLAMPUR, UTTAR DINAJPUR, 733207, WEST BENGAL

Sub: Fire Safety Certificate for the occupancy of a newly constructed of Partly G+1 Storied School Building in the name of Mount Litera Zee School under group of Educational Building at the premises of Mouza - Madaripur, J.L. No. - 22, Khatian No. - 1011, 1014, 854, 863, 862, Plot No. - 892, 889, 890, Village - Madaripur, Ramgnaj -II, P.O. - Shrikrishanpur, P.S. - Islampur, Uttar Dinajpur, 733207, West Bengal.

This is in reference to your application no. 0125189240600007 dated 08-02-2024 regarding the Fire Safety Certificate for the occupancy of a newly constructed of Partly G+1 Storied School Building in the name of Mount Litera Zee School under group of Educational Building at the premises of Mouza - Madaripur, J.L. No. - 22, Khatian No. - 1011, 1014, 854, 863, 862, Plot No. - 892, 889, 890, Village - Madaripur, Ramgnaj -II, P.O. - Shrikrishanpur, P.S. - Islampur, Uttar Dinajpur, 733207, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

/ TEC(Siliguri) Note-Standby pump to be installed before next renewal. */*

01. Driveway must have to be kept free of obstruction at all time for easy movement of fire Appliances. No parking will be allowed on the driveway.
02. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Building shall be strictly maintained.
03. Existing lift shall be treated as fire lift in case of emergency.
04. Existing Electrical wiring of the whole building shall have to be carefully checked for any damage in wear and tear in them, particularly lines above false ceiling & ducts.
05. A fire control room including a close circuit T.V./ Monitor system will have to be installed which will observe all the floor of the Building.

U. B. Roy
Principal
Mount Litera Zee School
Madaripur, Islampur

P. S. Roy
Chairman
Mount Litera Zee School
Madaripur, Islampur

06. The notice of Fire Fighting equipment's and Evacuation plan shall be maintained and displayed at all venerable places of the Building.
07. The Employees and security staff shall be well conversant with installed Fire Fighting Equipment's of the building and to operate in the event of Fire and Testing.
08. Mock Fire practice evacuation drill shall to be performed periodically with participant of all the occupants of the building.
09. Transformer and switch gear room with main and meter room shall be protected with sufficient ABC Modular / Co2 / DCP Fire Extinguishers confirming I.S. Specifications.
10. If required, the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
11. Arrangement shall have to be made for regular checking, testing and maintenance, of all the Fire Fighting installation of the Building to keep them in perfectly good working Condition at all the time.
12. Periodical Flashing of water in hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
13. A crew of trained Fire Men under an experience Officer shall be maintained round the clock for safety of the building.
14. Fire Safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
15. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
16. This Renewal of Fire Safety Certificate is valid for 3 (Three) years and have to be renewed every three years' interval from the date of Issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the Performance of all the life & Fire Safety arrangements and installation of the Building.
17. Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this Department, this Renewal of Fire Safety Certificate will be treated cancelled automatically.

Signature valid

Digitally Signed:
Name: DEBTAJ GUPTA
Date: 23-Feb-2024 12:31
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Darjeeling Division
West Bengal Fire & Emergency Services

U. B. Ray
Principal
Mount Litera Zee School
Madaripur, Islampur

P. Jana
Chairman
Mount Litera Zee School
Madaripur, Islampur